



65 Dundas St. E.  
Paris, Ontario  
N3L 3H1  
Toll Free: 1-877-871-2215  
519-442-2215  
www.brantcountypower.com

---

## **Conditions for Installation of Underground Services**

### **(Planned Subdivisions)**

1. All meters to be located on same side as service stub
2. Trench to be 4 feet deep ( 30” to 36” cover).
3. Bottom to be level and free of rocks and other debris.
4. **Excavation at street line to be such that the exposed service conductors are bedded in sand and lying flat (no loop up) and exposing a minimum 18” undamaged cable.**
5. Excavation at street line to be large enough for B.C.P. staff to make necessary connections from the pit with room to maneuver tools.
6. Perforated drainage pipe, cloth covered or 4” PVC Type 2 Rigid conduit with 3/8 “ rope, to be installed from street line to ground level at service entrance, in sand (**6”above and below**).
7. Backfill material to be free of rocks and debris that would cause pipe to collapse.  
**\*NOTE: Trench MUST be inspected by Brant County Power before backfill – CONNECTION will not proceed without prior inspection.**
8. Brant County Power has the right to ask customer to remove any backfill when in doubt about the quality of workmanship at customer’s expense.
9. Customer will be responsible for all travel time including any additional trips to complete the connections and labour to make connections in transformer and at street.
10. Trench must be backfilled at time of connection at the house and before service is energized.
11. All documentation must be completed prior to any service connection. Documentation shall include:
  1. Electrical Safety Authority connection authorization
  2. Service application completed by customer
  3. Work order for labour and materials signed and deposit paid
12. For services in new subdivisions a **\$250.00** deposit is required.
13. All work to be scheduled and coordinated with Brant County Power.